


DRAWN: SIMON	 ANCHORAGE TANK & WELDING, INC. 2723 RAMPART DRIVE ANCHORAGE, ALASKA (907) 272-3543
DATE: 03/14/22	
FILE NAME: STANDARD	ANCHORAGE TANK & WELDING, INC STANDARD SEPTIC TANK FOR
JOB NO: STANDARD	
SCALE: NTS	
SHEET No. 1 OF 1	

APPROX. GALLONS	STEEL GAUGE	DIAM. INCHES (A)	LGTH FEET (B)	COMP. 1 LGTH (C)	COMP. 2 LGTH (D)	
1000 (2)	12	59	8	5'-4"	2'-8"	STD.
1250 (2)	12	59	10	6'-8"	3'-4"	STD.
1500 (2)	12	59	12	8'-0"	4'-0"	STD.
1500 (2)	10	59	12	8'-0"	4'-0"	SPECIAL ORDER
2000 (2)	3/16	59	16	10'-8"	5'-4"	
2000 (2)	10	59	16	10'-8"	5'-4"	STD.

